


<u>Company Name</u>	SUNDOG SOLAR, INC.	
<u>Client Name</u>	PV Trainer	
<u>System:</u> PV Trainer	<u>Date:</u> July 27, 2011	

100 A Main service
120/240V
w/100A busbar
rating, A/C
Inverter output
will Feed 15A
SP Breaker



Battery Bank Size	Battery Make/Model	Charge input A max	Charge PV input V max.	Charge output A max.	Charge output V max.
1 Bank @ 12V	12V	25 A	30 V	A	V
System Size	Module Make	# Modules in String	PV String Voc @ STC	PV String Isc @ STC	Array Power @ STC
85W	Yingli 85W	3 Strings of 1 mods.	22 V	5.36 A	85W